



Environmental and Laboratory Services
90 ½ West Blackwell St., Dover, New Jersey 07801
(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: March 17, 2017

Client: Roseland BOE
Address: 100 Passaic Ave.
Roseland, NJ 07068

Project: Lester C. Noecker School

Sample description: Drinking Water / 1st Draw / DWS4959-1
Sample location: Field Blank
Sampled by: D. Diaz
Sample date: 03/09/17
Time: 06:30
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	17:49	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-2
Sample location: Room 204 Kitchen Sink 1
Sampled by: D. Diaz
Sample date: 03/09/17
Time: 06:31
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.37 µg/L	15 µg/L	03/15/17	18:02	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-3
Sample location: Room 204 Kitchen Sink 2
Sampled by: D. Diaz
Sample date: 03/09/17
Time: 06:32
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.64 µg/L	15 µg/L	03/15/17	18:09	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-4
 Sample location: Room 204 Kitchen Pot Filler Sink 3
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:33
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.0 µg/L	15 µg/L	03/15/17	18:16	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-5
 Sample location: Room 204 Kitchen Sink 4
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:34
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	18:22	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-6
 Sample location: Room 220 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:37
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	18:28	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-7
 Sample location: Room 221 Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:38
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.02 µg/L	15 µg/L	03/15/17	18:34	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-8
 Sample location: Room 231 Bubbler
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:40
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	18:41	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-9
 Sample location: Room 135 Chiller
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:41
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	18:47	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-10
 Sample location: Room 115 Bubblers with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:43
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.30 µg/L	15 µg/L	03/15/17	18:53	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-11
 Sample location: Room 111 Bubblers with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:45
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	19:00	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-12
 Sample location: Room 107 Bubblers with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:46
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.22 µg/L	15 µg/L	03/15/17	19:25	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-13
 Sample location: Room 103 Bubblers with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:48
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	34.4 µg/L	15 µg/L	03/15/17	19:53	2	4 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-14
 Sample location: Hallway by Room 522 Chiller 1
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:49
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	20:00	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-15
 Sample location: Hallway by Room 522 Chiller 2
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:50
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	20:06	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-16
 Sample location: Room 101 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:52
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.52 µg/L	15 µg/L	03/15/17	20:13	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-17
 Sample location: Room 105 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:54
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.60 µg/L	15 µg/L	03/15/17	20:19	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-18
 Sample location: Room 109 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:55
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	12.0 µg/L	15 µg/L	03/15/17	20:26	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-19
 Sample location: Room 113 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 06:57
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	194 µg/L	15 µg/L	03/15/17	20:41	10	20 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-20
 Sample location: Room 122 Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:00
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	20:54	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-21
 Sample location: Hallway by Room 131 Chiller 1
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:02
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.10 µg/L	15 µg/L	03/15/17	21:00	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-22
 Sample location: Hallway by Room 131 Chiller 2
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:03
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	21:07	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-23
 Sample location: Room 411 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:04
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	21:13	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-24
 Sample location: Room 421 Chiller 1
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:05
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	21:19	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-25
 Sample location: Room 421 Chiller 2
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:06
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	21:25	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-26
 Sample location: Hallway by Room 513 Chiller 1
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:09
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	21:32	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-27
 Sample location: Hallway by Room 513 Chiller 2
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:10
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	21:38	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-28
 Sample location: Room 429 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:11
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	21:45	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-29
 Sample location: Room 427 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:12
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	21:51	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-30
 Sample location: Room 426 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:13
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	22:10	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-31
 Sample location: Room 423 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:15
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	22:23	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-32
 Sample location: Room 369 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:17
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.54 µg/L	15 µg/L	03/15/17	22:47	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-33
 Sample location: Room 371 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:18
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.35 µg/L	15 µg/L	03/15/17	22:53	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-34
 Sample location: Room 373 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:20
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.28 µg/L	15 µg/L	03/15/17	22:59	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-35
 Sample location: Room 375 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:21
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.20 µg/L	15 µg/L	03/15/17	23:05	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-36
 Sample location: Room 374 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:22
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.10 µg/L	15 µg/L	03/15/17	23:11	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-37
 Sample location: Room 372 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:23
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.10 µg/L	15 µg/L	03/15/17	23:17	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-38
 Sample location: Room 370 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:24
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	693 µg/L	15 µg/L	03/16/17	18:59	100	200 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-39
 Sample location: Room 368 Bubbler with Sink
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:26
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	13.5 µg/L	15 µg/L	03/15/17	23:41	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-40
 Sample location: Hallway by Room 208 Chiller 1
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:27
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	23:48	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4959-41
 Sample location: Hallway by Room 208 Chiller 2
 Sampled by: D. Diaz
 Sample date: 03/09/17
 Time: 07:28
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/15/17	23:53	1	2 µg/L

µg/L = micrograms per liter


All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen (For SV)
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

March 20, 2017
 Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Lester C. Noecker School	report to:	Agra Environmental Services
Address: 100 Passaic Ave	Tom August	90½ West Blackwell Street
Roseland, NJ 07068	taugust@roselandnjboe.org	Dover, NJ 07801
County/Municipality:		Phone: (973) 989-0010
Phone: 973-226-7644 x319		Fax: (973) 989-0156
Work:		

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project:	Collection	PWSID# NJ							for laboratory use only	Field Analysis		
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED			
Field Blank	DNS4959	3/9/17	0630	D		X	1	HNO3	Pb 1st draw <2 µg/L	3/15/17	1749	SM
Rm 204 Kitchen Sink 1			0631	D		X	1	HNO3	Pb 1st draw 3.37 µg/L		1802	
Rm 204 Kitchen Sink 2			0632	D		X	1	HNO3	Pb 1st draw 3.64 µg/L		1809	
Rm 204 Kitchen Pot Filler Sink 3			0633	D		X	1	HNO3	Pb 1st draw 2.0 µg/L		1816	
Rm 204 Kitchen Sink 4			0634	D		X	1	HNO3	Pb 1st draw <2 µg/L		1822	
Rm 220 Bubbler with Sink			0637	D		X	1	HNO3	Pb 1st draw <2 µg/L		1828	
Rm 221 Sink			0638	D		X	1	HNO3	Pb 1st draw 4.02 µg/L		1834	
Rm 231 Bubbler			0640	D		X	1	HNO3	Pb 1st draw <2 µg/L		1841	
Rm 135 Chiller			0641	D		X	1	HNO3	Pb 1st draw <2 µg/L		1847	
Rm 115 Bubbler with Sink			0643	D		X	1	HNO3	Pb 1st draw 2.30 µg/L		1853	

Sampled By (name/company): <i>J. Diaz (Agra)</i>	State Forms Needed (circle one): Yes or <u>No</u>	indicate laboratory location where analysis requested was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Standard <input type="checkbox"/>	NJ Reduced <input type="checkbox"/>
		Other (Specify) <input type="checkbox"/>
		Cooler Temperature Upon Receipt at lab: <i>8.4°C</i>

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <i>[Signature]</i>	Date: 3/9/17	Time: 1220	Received By: <i>[Signature]</i>	Date: 3/9/17	Time: 1205	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Lester C. Noecker School	report to:	Agra Environmental Services
Address: 100 Passaic Ave	Tom August	90½ West Blackwell Street
Roseland, NJ 07068	taugust@roselandnjboe.org	Dover, NJ 07801
County/Municipality:		Phone: (973) 989-0010
Phone: 973-226-7644 x319		Fax: (973) 989-0156
Work:		



Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project:	Collection	PWSID# NJ						for laboratory use only	Field Analysis
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
Rm 111 Bubbler with Sink	DWS4959	3/9/17	0645	D		X	1	HNO3	Pb 1st draw <2 µg/L 3/15/17 1900
Rm 107 Bubbler with Sink			0646	D		X	1	HNO3	Pb 1st draw 7.22 µg/L 1925
Rm 103 Bubbler with Sink			0648	D		X	1	HNO3	Pb 1st draw 34.4 µg/L 1953
Hallway by Rm 522 Chiller 1			0649	D		X	1	HNO3	Pb 1st draw <2 µg/L 2000
Hallway by Rm 522 Chiller 2			0650	D		X	1	HNO3	Pb 1st draw <2 µg/L 2006
Rm 101 Bubbler with Sink			0652	D		X	1	HNO3	Pb 1st draw 2.52 µg/L 2013
Rm 105 Bubbler with Sink			0654	D		X	1	HNO3	Pb 1st draw 5.60 µg/L 2019
Rm 109 Bubbler with Sink			0655	D		X	1	HNO3	Pb 1st draw 12.0 µg/L 2026
Rm 113 Bubbler with Sink			0657	D		X	1	HNO3	Pb 1st draw 194 µg/L 2041
Rm 122 Sink			0700	D		X	1	HNO3	Pb 1st draw <2 µg/L 2054

Sampled By (name/company): <i>D. Diaz / Agra</i>	State Forms Needed (circle one): Yes or No	indicate laboratory location where analysis requested was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	

Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab: <i>8.4°C</i>
-------------------------------------	----------	------------	-----------------	---

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <i>L. Noecker</i>	Date: <i>3/9/17</i>	Time: <i>1220</i>	Received By: <i>Shawn Pate</i>	Date: <i>3/9/17</i>	Time: <i>1305</i>	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Lester C. Noecker School	report to:	Agra Environmental Services
Address: 100 Passaic Ave Roseland, NJ 07068	Tom August taugust@roselandnjboe.org	90½ West Blackwell Street Dover, NJ 07801
County/Municipality:		Phone: (973) 989-0010
Phone: 973-226-7644 x319		Fax: (973) 989-0156
Work:		



Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project:	Collection	PWSID# NJ							for laboratory use only	Field Analysis			
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED				
Hallway by Rm 131 Chiller 1	DWS4959	3/9/17	0702	D		X	1	HNO3	Pb 1st draw	5.10 ug/L	3/15/17	2100	BM
Hallway by Rm 131 Chiller 2			0703	D		X	1	HNO3	Pb 1st draw	<2 ug/L		2107	
Rm 411 Bubbler with Sink			0704	D		X	1	HNO3	Pb 1st draw	<2 ug/L		2113	
Rm 421 Chiller 1			0705	D		X	1	HNO3	Pb 1st draw	<2 ug/L		2119	
Rm 421 Chiller 2			0706	D		X	1	HNO3	Pb 1st draw	<2 ug/L		2125	
Hallway by Rm 513 Chiller 1			0709	D		X	1	HNO3	Pb 1st draw	<2 ug/L		2132	
Hallway by Rm 513 Bubbler with Sink			0710	D		X	1	HNO3	Pb 1st draw	<2 ug/L		2138	
Rm 429 Bubbler with Sink			0711	D		X	1	HNO3	Pb 1st draw	<2 ug/L		2145	
Rm 427 Bubbler with Sink			0712	D		X	1	HNO3	Pb 1st draw	<2 ug/L		2151	
Rm 426 Bubbler with Sink			0713	D		X	1	HNO3	Pb 1st draw	<2 ug/L		2210	

Sampled By (name/company): D. Diaz (Agra)

State Forms Needed (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

indicate laboratory location where analysis requested was performed

Reporting Requirements (Check Box):

Standard NJ Reduced Other (Specify)

Cooler Temperature Upon Receipt at lab: 8.4°C

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <u>[Signature]</u>	Date: <u>3/9/17</u>	Time: <u>1220</u>	Received By: <u>[Signature]</u>	Date: <u>3/9/17</u>	Time: <u>1305</u>	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____
						Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Lester C. Noecker School	report to:	Agra Environmental Services
Address: 100 Passaic Ave	Tom August	90½ West Blackwell Street
Roseland, NJ 07068	taugust@roselandnjboe.org	Dover, NJ 07801
County/Municipality:		Phone: (973) 989-0010
Phone: 973-226-7644 x319		Fax: (973) 989-0156
Work:		



Matrix Abbreviations: D - Drinking Water G - Groundwater W - Wastewater S - Soil SL - Sludge P - Pool L - Lake Page 1 of 1

Project:	Collection	PWSID# NJ							for laboratory use only	Field Analysis		
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED			
Rm 423 Bubbler with Sink	BWS4959	3/19/17	0715	D		X	1	HNO3	Pb 1st draw < 2 µg/L	3/15/17	2223	BM
Rm 369 Bubbler with Sink	-32		0717	D		X	1	HNO3	Pb 1st draw 2.54 µg/L		2247	
Rm 371 Bubbler with Sink	-33		0718	D		X	1	HNO3	Pb 1st draw 2.35 µg/L		2253	
Rm 373 Bubbler with Sink	-34		0720	D		X	1	HNO3	Pb 1st draw 3.28 µg/L		2259	
Rm 375 Bubbler with Sink	-35		0721	D		X	1	HNO3	Pb 1st draw 3.20 µg/L		2305	
Rm 374 Bubbler with Sink	-36		0722	D		X	1	HNO3	Pb 1st draw 5.10 µg/L		2311	
Rm 372 Bubbler with Sink	-37		0723	D		X	1	HNO3	Pb 1st draw 3.10 µg/L		2317	
Rm 370 Bubbler with Sink	-38		0724	D		X	1	HNO3	Pb 1st draw 6.93 µg/L	3/16/17	1859	BM
Rm 368 Bubbler with Sink	-39		0724	D		X	1	HNO3	Pb 1st draw 13.5 µg/L	3/15/17	2341	BM
Hallway by Rm 208 Chiller 1	-40		0727	D		X	1	HNO3	Pb 1st draw < 2 µg/L		2348	

Sampled By (name/company): <i>D. Diaz / Agra</i>	State Forms Needed (circle one): Yes or No				indicate laboratory location where analysis requested was performed		
	NJDEP Laboratory Certification (Dover, NJ) #14013						
	NJDEP Laboratory Certification (Marlboro, NJ) #13033						
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab: <i>8.4°C</i>			

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <i>[Signature]</i>	Date: 3/9/17	Time: 1220	Received By: <i>[Signature]</i>	Date: 3/9/17	Time: 1305	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____
						Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Lester C. Noecker School	report to:	Agra Environmental Services	
Address: 100 Passaic Ave	Tom August	90½ West Blackwell Street	
Roseland, NJ 07068	taugust@roselandnjboe.org	Dover, NJ 07801	
County/Municipality:		Phone: (973) 989-0010	
Phone: 973-226-7644 x319		Fax: (973) 989-0156	
Work:			

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project:		Collection		PWSID# NJ					for laboratory use only	Field Analysis		
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED			
Hallway by Rm 208 Chiller 2	DW54959	3/9/17	0728	D		X	1	HNO3	Pb 1st draw < 2 µg/l	3/15/17	2353	BM

Sampled By (name/company): <i>D. Diaz / Agra</i>	State Forms Needed (circle one): Yes or No				indicate laboratory location where analysis requested was performed		
	NJDEP Laboratory Certification (Dover, NJ) #14013						
	NJDEP Laboratory Certification (Marlboro, NJ) #13033						
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab: <i>8.4°C</i>			

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <i>Sherry Peto</i>	Date: <i>3/9/17</i>	Time: <i>1220</i>	Received By: <i>Sherry Peto</i>	Date: <i>3/9/17</i>	Time: <i>1305</i>	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
						Date Faxed _____
						Invoice Number _____
						Is sample known to be hazardous? (circle one) Yes or No